

## STRUCTURAL SOUNDNESS CERTIFICATE

### STATEMENT ACCOMPANYING FORM - A

- 1) Door number of the building : Nil
- 2) Location : **Vidhyalakshmi School,**  
( Street number, Ward number, Keelpudur Village,  
Name of place, i.e. Corporation / Chennangkuppam Post - 632 209,  
Municipality / Panchayat Union / S.F. No. 359/7, 359/8 & 360/1,  
Township / Contonment ) Keelpudur Village,  
K.V. Kuppam Taluk,  
Vellore District.
- 3) Year of construction : 2012, 2014 & 2017
- 4) Approximate cost of construction : Rs. 7,88,00,000/-  
as per current rates
- 5) Purpose for which the building is : School purpose  
being used or proposed to be used (CBSE)
- 6) Purpose for which the building : School purpose  
has hitherto been used (CBSE)
- 7) Details of construction of the building  
( Particulars of the foundations soil,  
Specification of various parts under )
  - a) Foundation : RCC column & footing
  - b) Basement : RCC column & plinth beam
  - c) Super structure : Brick walls in cement mortar
  - d) Floor and roof are to be given : Floor Roof Area  
 : Ground floor RCC roof 26274.74 sqft  
 : First floor RCC roof 26274.74 sqft  
 : Second floor RCC roof 26274.74 sqft
- 8) Period for which licence is required : **01.06.2021 to 31.05.2024.**



9) No. of persons to be accommodated : **3092 Students only.**

(Three thousand nintytwo students only)

**Date : 03.07.2021**

Encl :- 1. Declaration

2. Vellore Collector Panel order

3. Blue print

Proceedings of V.  
Collector R. Dist 9624/200

**Signature of the Panel Engineer**

**Er. P.N. RAMESH BABU,**  
B.E., M.Tech., M.Sc.(R&V), MIE, FIV, FICV, C.Eng(I), MIIA, MICI,  
Chartered Engineer (M-119995-6/99)  
Govt. Approved Valuer (F-1410)  
Regd. Valuer for Wealth Tax (C-I/443-99)  
Approved Valuer for Immovable Properties (F-5636)  
Regd. Engineer Class 1A (TN Public Buildings Act)  
Panel Valuer for Banks, NBFI, IOCL, IFCI & HUDCO  
**TLR ASSOCIATES**  
Mobile: 94434 42002. Email : tlrasociates@yahoo.com

Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh licence in case any addition or alteration is made to the existing building or portion of building. I also undertake to obtain a fresh licence if the purpose for which the licence was granted for the use of the building or portion of building originally is changed or altered subsequently.

This is further to certify that no thatched buildings / inflammable roof buildings are used within this premises for the purpose noted in the statement. Any thatched building constructed / used after issue of this certificate, I would be held responsible for fire accident / mishap that may occur later and I am aware of that it is a punishable crime.

It is also understood that the conditions of all existing, adjacent / other floors/ or other buildings of any types within this premises which were not opted / covered for the purpose which the licence was granted would be brought under the risk of my own.

We are well aware of that the underground amenities like water sumps, septic tanks, borewells and open wells should be kept always in closed rigid conditions for all time safety measures to students / publics.

**Date : 03.07.2021**

**Signature of the owner of the building**



**STATEMENT FORM - B COMPANY**

(Form of Certificate of Structural Soundness under sub-section(4) of section 4 of the Tamilnadu Public Buildings (Licensing) Act 1965 (Tamil Nadu Act 13 of 1965) referred to in rule 4 of the Tamilnadu Public Buildings (Licensing) Rules 1966).

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features.

**1) Foundation :**

- |   |   |                       |
|---|---|-----------------------|
| i) Depth below ground level   | : | 2.44 m                |
| ii) Nature of soil met with at foundation level                         | : | Hard Gravel           |
| iii) Pressure at foundation   | : | 100 kN/m <sup>2</sup> |
| iv) Probable safe bearing capacity of the strata met with at foundation | : | 300 kN/m <sup>2</sup> |

**2) Super structure :**

- |  |   |  |
|--|---|--|
| i) Maximum stress in the most critical section of masonry and concrete | : | Masonry - 0.20 N/mm <sup>2</sup><br>Concrete - 5.00 N/mm <sup>2</sup>    |
| ii) Nature of Masonry & Concrete and its safe permissible stress       | : | Brick work - 0.35 N/mm <sup>2</sup><br>Concrete - 9.00 N/mm <sup>2</sup> |

The structural soundness of the building has been verified by me with reference to ISI loading standards 875 (latest version) and other relevant Indian Standard Code of practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A licence may be granted for the period from

01.06.2021 to 31.05.2024.

Date : 03.07.2021

Signature of the Panel Engineer

Proceedings of Vellore Dist  
Collector R. Dist 9624/200"

Er. R. RAMESH, P.E.T.U.  
B.E.M.Tech, M.Sc(R.V.M.E.F.V), F.R.V.C. Eng(I), M.I.T.A, M.C.I.  
Chartered Engineer (M-119935-6/99)  
Govt. Approved Valuer (F-1410)  
Regd. Valuer for Wealth Tax (C-1/443-99)  
Approved Valuer for Immovable Properties (F-5536)  
Regd. Engineer Class 1A (TN Public Buildings Act)  
Panel Valuer for Banks, NSFI, IOCL, IFCI & HUDCO  
T.R. ASSOCIATES  
Mobile: 91434 42002. Email : trassociates@yahoo.com


**STATEMENT TO ACCOMPANY****THE CERTIFICATE OF STRUCTURAL SOUNDNESS**

1)	Location of the building (Door No, street name and name of the place)	<b>Vidhyalakshmi School,</b> Keelpudur Village, Chennangkuppam Post - 632 209, S.F. No. 359/7, 359/8 & 360/1, Keelpudur Village, K.V. Kuppam Taluk, Vellore District.
2)	Age of the building	9 & 7 & 4 Years
3)	The Value of the building as per current rate	Rs. 7,88,00,000/-
4)	Number of Storeys	G + 2
5)	Short description of structures (Steel/RCC framed/Loadbearing)	RCC column & footing
6)	Purpose for which the building is certified for use	School purpose (CBSE)
7)	The period for which the building will be structurally sound	<b>01.06.2021 to 31.05.2024.</b>
8)	No. of persons to be accommodated	<b>3092 Students only.</b> (Three thousand nintytwo students only)
9)	Remarks	Nil

Date : 03.07.2021

Signature of the Panel Engineer

Proceedings of Vellore Dist  
Collector R. Dist 9824/200





**FORM - C**

(Form of Certificate of Structural Soundness under sub-section (4) of section 4 of the Tamilnadu Public Buildings (Licensing) Act 1965 (Tamilnadu Act 13 of 1965) referred to in rule 4 of the Tamilnadu Public Buildings (Licensing) Rules 1966)

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features.

**1) Foundation :**

- |   |   |                       |
|---|---|-----------------------|
| i) Depth below ground level   | : | 2.44 m                |
| ii) Nature of soil met with at foundation level                         | : | Hard Gravel           |
| iii) Pressure at foundation   | : | 100 kN/m <sup>2</sup> |
| iv) Probable safe bearing capacity of the strata met with at foundation | : | 300 kN/m <sup>2</sup> |

**2) Super structure :**

- |  |   |  |
|--|---|--|
| i) Maximum stress in the most critical section of masonry and concrete | : | Masonry - 0.20 N/mm <sup>2</sup><br>Concrete - 5.00 N/mm <sup>2</sup>    |
| ii) Nature of Masonry & Concrete and its safe permissible stress       | : | Brick work - 0.35 N/mm <sup>2</sup><br>Concrete - 9.00 N/mm <sup>2</sup> |

The structural soundness of the building has been verified by me with reference to ISI loading standards 875 (latest version) and other relevant Indian Standard Code of practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A licence may be granted for the period from

**01.06.2021 to 31.05.2024.**

Date : 03.07.2021

Signature of the Panel Engineer

Proceedings of Vellore Dist  
Collector R Dist 9824/200

**ER. R. RAMESH** / ENU,  
B.E., M.Tech., M.Sc.(R+V), MIE, FV, FV-C, Engg., MITA, MICI,  
Chartered Engineer (M-1: 9935-6/99)  
Govt. Approved Valuer (F-1410)  
Regd. Valuer for Wealth Tax (D-8443-99)  
Approved Valuer for Immovable Properties (F-5636)  
Regd. Engineer Class 1A (TN Public Buildings Act)  
Panel Valuer for Banks, REIR, IOCL, IFCI & HUDCO  
T.R. ASSOCIATES  
Mobile: 94434 42002, Email: trassociates@yahoo.com

**STATEMENT TO ACCOMPANY**

**THE CERTIFICATE OF STRUCTURAL SOUNDNESS**

1)	Location of the building (Door No, street name and name of the place)	<b>Vidhyalakshmi School,</b> Keelpudur Village, Chennangkuppam Post - 632 209, S.F. No. 359/7, 359/8 & 360/1, Keelpudur Village, K.V. Kuppam Taluk, Vellore District.
2)	Age of the building	9 & 7 & 4 Years
3)	The Value of the building as per current rate	Rs. 7,88,00,000/-
4)	Number of Storeys	G + 2
5)	Short description of structures (Steel/RCC framed/Loadbearing)	RCC column & footing
6)	Purpose for which the building is certified for use	School purpose (CBSE)
7)	The period for which the building will be structurally sound	<b>01.06.2021 to 31.05.2024.</b>
8)	No. of persons to be accommodated	<b>3092 Students only.</b> (Three thousand nintytwo students only)
9)	Remarks	Nil

Date : 03.07.2021

Signature of the Panel Engineer

**Er. P.N. RAMESH**, **B.E., B.Tech.**  
**B.E., M.Tech., M.Sc (R&V), MIE, FIV, FICV, C. Eng (I), MITA, MICI,**  
 Chartered Engineer (M-119935-6/99)  
 Govt. Approved Valuer (F-1410)  
 Regd. Valuer for Wealth Tax (C-1443-99)  
 Approved Valuer for Immovable Properties (F-5636)  
 Regd. Engineer Class 1A (TN Public Buildings Act)  
 Panel Valuer for Banks, NEFT, IOCL, IFCI & HUDCO  
**T.R. ASSOCIATES**  
 Mobile: 94437 4200 Fax: 4200 tes@yahoo.com

Proceedings of Vellore Dist  
 Collector R. Dist 9624/200\*